

OFFICE OF THE ASST. FIRE OFFICER, FIRE STATION CUTTACK.

L.No 861 (2)/CFS, Date. 6.6.14.

To The Principal JOHARIMALL HIGH SCHOOL
(English Medium), Ganeshtal, Cuttack - Orissa.

Subj: - Fire Safety Measure Report

Ref: - Your Letter No. F-JHS/Certificate No. 1192/2014 Dated 13.5.2014

In connection to your request letter under ref. Joharimall High School building, Cuttack was inspected by the Asst. Fire Officer Fire Station Cuttack and the following are observations and inferences:

- 1) The Joharimall High School Cuttack is functioning in a G+3 building about 100 feet road from Dalubazar to straight with ^{at} side ~~side~~ but with backstop space surrounded by boundary walls.
 2. As the said building was constructed before 1980 this has not been presently approved by Cuttack Development Authority. There are 503 students & staff and office are in occupation.
 3. The building is having staircase on alternate staircase open balconies on of class rooms, Electric panel on 1st floor and terrace water tank etc.
 4. No potential fire hazards are seen very near to the school at the time of visit.
- The following fire protection arrangements are available in the school building at the time of visit.
- a) 05 nos. ABC portable fire extinguishers - 05 nos are available and distributed in the school building
 - b) Fire buckets with sand available - 04 nos.

Recommendation: -


- A) Water Co₂ - 04 lbs capacity fire extinguishers - 04 nos should be installed at corridor of each floor.
- B) Water Hose reel system with fire pump - 03 nos in each floor.
- C) Terrace water tank of 10,000 litres capacity should be provided.
- D) All exits entrances should be marked with self-illuminated sign boards on face of each door.
- E) All electrical fittings and installation should be checked by local electrical authority periodically.
- F) No open flame or similar activities be allowed in the

G) Mock Fire Drill should be carried out twice
in a year.

Hence the School in question may be allowed to function with
above terms and conditions and ^{also} ~~subject~~ to annual verification.

This is your kind information and necessary action
Please.

Yours faithfully,


G. B. M.
(Car. Nator)
Asst. Fire Officer
Fire Station, Cuttak